



List of Materials

Item	Description
1	8" Cast iron 'valve box' cover (see Note 1) by Eisel Enterprises, Inc. Model #W106C.
2	8" O.D. X 20 GA. galvanized valve can (18" long min.) by RK Industries.
3	Riser Pipe - 8" PVC (C-900) DR 18 pipe.

Notes:

1. Cast iron cover shall have standard cover marking "WATER".
2. Backfill and resurface per Section 2 of these Specifications and as directed by Engineer.
3. Concrete donut shall be Class 560-C-3250.
4. Valve stem extensions required if depth to valve nut exceeds 6 feet, per Standard Drawing 651. The City shall approve all extensions.
5. Contractor shall raise slip can to grade when paving street.

REVISED DATE _____ _____ _____ _____	CITY OF COMPTON PUBLIC WORKS DEPARTMENT - WATER UTILITY DIVISION	DRAWN <u>L.H.O.</u> DATE <u>8-25-15</u>	
	STANDARD VALVE BOX ASSEMBLY	STD. NO. 650	
	APPROVED <u>[Signature]</u> DIRECTOR OF PUBLIC WORKS AND MUNICIPAL UTILITIES	DATE <u>9.1.15</u>	