



### List of Materials

Item	Description
1	Steel valve stem extension, Pipeline Products part number SX-906 or approved equal.

### Notes:

1. Provide valve stem extension when depth from finished grade to operating nut exceeds 6 feet.
2. Terminate extension 24" to 36" from finished grade.
3. No valve stem extension shall be less than 2 feet in length.
4. Fabricate extension to field measurement.
5. Provide additional locating ring when distance to bottom socket exceeds 5 feet.
6. The valve stem extension shall be of solid design, pinned couplers are unacceptable.
7. Stem shall not be pinned or attached by any other means to the valve nut.
8. See Section 5-10 of these Specifications for painting requirements.

<b>REVISED</b> DATE _____ _____ _____ _____	<b>CITY OF COMPTON</b> PUBLIC WORKS DEPARTMENT – WATER UTILITY DIVISION	DRAWN <u>L.H.O.</u> DATE <u>8-25-15</u>
	<b>STEEL VALVE STEM EXTENSION</b>	<b>STD. NO.</b> <b>651</b>
	APPROVED <u><i>[Signature]</i></u> DIRECTOR OF PUBLIC WORKS AND MUNICIPAL UTILITIES	DATE <u>9.1.15</u>